



SECTION

Notes:

1. All dimensions are in millimetres, unless otherwise stated.
2. All concrete to be grade 30/20, unless otherwise stated.
3. Movement joint to be provided at 10 metres intervals.
4. Minimum 50 cover to reinforcement.
5. Wall end details to be decided to suit site.
6. Stone to be specified in accordance with G.S. clause 24.192.
7. Where rubble stone walling is specified, G.S. clause 24.199 to 24.201 should be complied with.
8. Landscape Unit/HyD should be consulted on stone facing pattern and planting species.
9. Changes in drainage details subject to approval by Highways Engineer & Landscape Unit/HyD.
10. Width of planter shown as 600 min. for accommodating tree planting ; it may be decreased if for shrub & climber planting as specified and/or approved by Landscape Unit/HyD.

A	Notes 6 & 7 reference to the G.S. updated		Apr 10
	New issue		May 97
REF.	REVISION	SIGNATURE	DATE

**TOE WALL PLANTER -
SHOTCRETED SLOPE
LESS THAN 50°
(SHEET 1 OF 2)**

HIGHWAYS DEPARTMENT

REFERENCE	DRAWING No.	CAD
SCALE 1 : 20	H 5110A	