



SECTION

Notes:

1. All dimensions are in millimetres.
2. All concrete to be grade 30/20, unless otherwise stated.
3. Movement joint to be provided at 10 metres intervals.
4. Minimum 50 cover to reinforcement.
5. Wall end details to be decided to suit site.
6. Stone to be specified in accordance with G.S. clause 24.192.
7. Where rubble stone walling is specified, G.S. clause 24.199 to 24.201 should be complied with.
8. Landscape Unit/HyD should be consulted on stone facing pattern and planting species.
9. Changes in drainage details subject to approval by Highways Engineer & Landscape Unit/HyD.

	New issue supersedes H5110A	Original signed	Aug 17
REF.	REVISION	SIGNATURE	DATE

**TOE WALL PLANTER -
SHOTCRETED SLOPE
(SHEET 1 OF 2)**

HIGHWAYS DEPARTMENT	
REFERENCE	DRAWING No. CAD
SCALE	H 5142
	1 : 20