

NOTES:

- 1. ALL DIMENSIONS ARE IN MILLIMETRES.
- 2. ALL LOOSE WIRES SHOULD BE BOUND NEATLY BY CABLE TIES.
- 3. EARTH WIRE TO BE SEPARATELY RUN & CONNECTED TO THE COLUMN EARTHING TERMINAL.

ITEM NO.	DESCRIPTION	
1.	MCB	
2.	STREET LIGHTING CUT-OUT BOX	
3.	ZINC PLATED BRASS CABLE GLAND ANCHOR PLATE	
4.	35mm ² POST SEAL CABLE GLAND C/W LOCK NUT	
5.	2.5mm ² 2/C XLPE/PVC Cu CABLE	
6.	2.5mm ² 1/C EARTH Cu CABLE	
7.	16mm ² 1/C EARTH Cu CABLE	
8.	CRIMPING LUG	

	New Issue		Jun 21
REF.	REVISION	SIGNATURE	DATE

TYPICAL LOOP-IN CONNECTION IN PUBLIC LIGHTING COLUMN RECESS FOR SINGLE-ARMED COLUMN WITH LED ROAD LIGHT

HIGHWAYS DEPARTMENT LIGHTING DIVISION

REFERENCE DRAWING No.

HLDSDHK01-CL2026

CAD

SCALE N.T.S.