





NOTE:

EARTH TAG

- 1. ALL DIMENSIONS ARE IN MILLIMETRES.
- 2. CABLE GLAND ANCHOR PLATE AND CABLE GLAND ADAPTOR PLATE SHALL BE OF ZINC PLATED BRASS.
- 3. THE TOOL USED AND THE WORKING
 PROCEDURE ADOPTED SHOULD BE AS
 RECOMMENDED BY THE CABLE
 MANUFACTURER.
- DETAILS AND MATERIAL OF EARTH TAGS SHALL BE APPROVED BY THE ENGINEER.

	Δ.	1
		-
55	Ø6- Ø6-	\
Ø6	D	E
	_E GLAND ADAPTO	R PLATE

		≤ 5.1m	≥ 8m
	А	95	115
(В	20	27
(С	35	15
[D	19	23
	E	19	35
l l	F	23	28
			CABLE
	G	32	25mm² 4/C
		25	25mm² 2/C
		20	4mm² 2/C

COLUMN HEIGHT

B Earth tag for earth bond connection is included

A General revision Mar 07

Former Drg. No. LDSDML01-CL0014A with general revision Feb 06

REF. REVISION SIGNATURE DATE

TYPICAL ARRANGEMENT OF CABLE TERMINATIONS FOR VARIOUS TYPES OF CABLES INSIDE A LIGHTING COLUMN

OR 1 NO 4mm² 2/C CABLE

HIGHWAYS DEPARTMENT LIGHTING DIVISION

REFERENCE DRAWING NO. CAD

SCALE

N.T.S.

CABLE ARRANGEMENT

1.5 THK

3 NOS. 25mm² 4/C CABLE

|HLDSDML06-CL1014B|