

NOTES:

1. ALL EQUIPMENT AND WIRINGS SHALL COMPLY WITH THE REQUIREMENTS OF THE CODE OF PRACTICE FOR THE ELECTRICITY (WIRING) REGULATIONS AND IEE WIRING REGULATIONS.
2. LABELS FOR THE EQUIPMENT SHALL BE PROVIDED.
3. OUTGOING CIRCUIT CABLES SHALL BE ATTACHED WITH NON-FERROUS CIRCUIT LABEL.
4. THE NUMBER OF OUT GOING CIRCUITS SHOWN ON THE DIAGRAM IS INDICATIVE ONLY AND SHALL NOT BE DEEMED TO BE FIXED. THE CONTRACTOR SHALL SUBMIT THE PROPOSED ARRANGEMENT FOR THE ENGINEER'S APPROVAL.
5. A WIRING DIAGRAM IN THE FORMAT APPROVED BY THE ENGINEER SHALL BE PREPARED, PERIODICALLY UPDATED AND PROPERLY AND SECURELY KEPT INSIDE THE PUBLIC LIGHTING CONTROL CUBICLE IN SUCH A MANNER THAT IT IS FREE FROM MOISTURE AND DAMAGE.

A	General revision of notes	Mar 07
	Former Drg. No. HLSDML02-CL0015B with general revision	Feb 06
REF.	REVISION	SIGNATURE DATE

GENERAL ARRANGEMENT OF PUBLIC LIGHTING  
CONTROL CUBICLE WIRING DIAGRAM (SHEET 1 OF 3)

<b>HIGHWAYS DEPARTMENT LIGHTING DIVISION</b>		
REFERENCE	DRAWING No.	CAD
SCALE N.T.S.	HLSDML06-CL1015A	