



- NOTES:**
- DIMENSIONS ARE IN MILLIMETRES
 - ALL WORKS TO BE SUPPLIED, INSTALLED & COMPLETED BY CIVIL CONTRACTOR UNLESS OTHERWISE SPECIFIED
 - THE P.V.C./G.I. DUCT FOR MAINS CABLE SHOULD BE TERMINATED INSIDE THE NEAREST CABLE DRAW PIT PROVIDED BY THE SUPPLY COMPANY EXACT ENTRY TO BE DECIDED ON SITE
 - SIZES, NUMBER & EXACT POSITIONS OF G.I. CONDUITS SHOULD BE REFERRED TO RELEVANT DRAWING(S)
 - ALL METAL SURFACE SHALL BE THOROUGHLY CLEANED DOWN TO REMOVE RUST BOTH INTERNALLY & EXTERNALLY, AND BE PAINTED WITH TWO COATS OF RED OXIDE PAINT. THE EXTERNAL SURFACE SHALL THEN BE PAINTED WITH A FINISH COAT OF LIGHT GREY COLOUR TO B.S. 381C:1964. CODE No. 631
 - THIS PILLAR BOX AND ASSOCIATED METAL WORKS TO BE PROVIDED BY CIVIL CONTRACTOR. REFERENCE TO BE MADE TO ELECTRICAL LAYOUT DRAWING FOR NOS. OF G.I. CONDUITS TO BE REQUIRED FOR LAYING FROM PILLAR BOX TO THE SUBWAYS.
 - THIS DRAWING IS BASED ON EM(10)-13718.

B	8.5.82	EARTHING DETAIL BASED ON I.H. 235 ADDED	
A	5.3.81	THIS DRG. SUPERSEDES DRG. No. S SD / 53	
no. date		description	initial
REVISION			
		name	date
surveyed			
designed			
drawn			
traced		S. K. Chu	5.3.81
checked		H. Tsang	12/3/81
approved			
contract no.			
file no.			
project no.			
contract			
drawing title			
STANDARD SUBWAY CONCRETE PILLAR BOX (1 200 W x 1 500 H) (SHEET 1 OF 3)			
drawing no.		scale	
S SD / 53 (1) ^B		1 : 5	
office			
STRUCTURES DIVISION			
HIGHWAYS DEPARTMENT		路 香港 政 署	
HONG KONG		署	
81 1000-707			