

Guideline for support of HGC external plant

Type of service : Telcom cable / duct

- Quantity and size of the supporting beams, and longitudinal beams will be subject to the weight and size of duct block.
- Max. distance between supports is 1.5 metres.
- Any broken duct should be well repaired.
- Any duct end should be sealed.
- Supporting work should be under HGC site supervision.

Type of service : Jointing chamber

- Quantity and size of the supporting beams, longitudinal beams will be subject to the weight and size of jointing chamber.
- Max. distance between supports is 1.5 metres.
- Access for emergency cable work should be maintained at all times.
- Supporting work should be under HGC site supervision.